

SKG-IKOB PRODUCTCERTIFICATE

441.633.03

Date of issue: 01-05-2023



Certificate holder

FKS Okucia Okienne I Drzwoiwe Sp zoo
Bronikowo, Morownicka 1c
P64-030 Smigiel
T: + 48 (0) 6551 88 024
E: fks@home.pl
I: www.fks.home.pl



Declaration of SKG-IKOB

This certificate has been issued on the basis of BRL 3104 in accordance with the SKG-IKOB Regulations for Attestation, Certification and Inspection.

SKG-IKOB declares that the by or on behalf of the certificate owner produced building hardware product:

Long plate

delivered under logo / brand:

FKS

delivered under type- and / or article number:

52SKG -KZ 72/92-H-01/02 , 52SKG-KZ72/92-FKS-01/02

meets class 3 STER according BRL 3104 and NEN 5089: 2009 if the product is indelibly marked with the SKG mark, as shown above.

For SKG-IKOB

A handwritten signature in blue ink, consisting of a stylized, cursive script.

ir. H.A.J. van Dartel
Certification manager

Verify at www.sterrenwijzer.nl if this certificate is still valid and actual.
This certificate contains 2 pages.

CERTIFICATE

SKG-IKOB Certificatie
Poppenbouwing 56
4191 NZ Geldermalsen

Postbus 202
4190 CE Geldermalsen

T 088-2440100
info@skgikob.nl
www.skgikob.nl

SKG-IKOB PRODUCTCERTIFICATE

FKS Okucia Okienne I Drzwoiwe Sp zoo
Number: 441.633.03

page 2 of 2

1. PRODUCT

Long plate

PRODUCT TYPE

security furniture

2. TECHNICAL SPECIFICATION

Operating:	Mechanical operation
Construction:	1 set of an outside part and an inside part with mounting screws
System:	various cylinder holes various handles square or rounded WITH cylinder protection
Material:	outside part: extruded aluminium, anodised or coated inside part: casted aluminium with ALU cover
Dimension:	outside part: 251x52x15 mm inside part: 251x52x8 mm
Fixing:	bolts: 3xM6x 55 mm (10.9) in steel cams, h.o.h. 97/113 mm
Intended use:	wood, PVC, metal in combination with mortice locks on doors

3. DELIVERY

The preconditions for correct installation and the fasteners to be used are described in the enclosed or digitally published installation instructions with the following version:
Instruction - 52SKG - version no.1

4. PERFORMANCES

A Long plate according this certificate fulfils the relevant requirements of BRL 3104.

A window- or door set, in which this Long plate is installed according the installation instructions of the certificate holder meets at least burglar resistance class (RC) 3 of NEN 5096 and EN 1627, if:

the façade element or the (profile-)system from which the element is manufactured is delivered under a (KOMO-)quality approval with respect to the aspect burglar resistance, in which the actual window or door type is admitted and the herein mentioned conditions are fulfilled.

A window or door, in existing buildings, in which this Long plate is installed according the installation instructions of the certificate holder, meets the requirements of the Police Mark Save Housing (PKVW) - Existing Building, if:

the other aspects of the façade element also comply with the applicable PKVW Protection directive (publication CCV).